

TURCK

Hans Turck GmbH & Co. KG
Witzlebenstr. 7 | 45472 Mülheim an der Ruhr, Germany
T +49 208 4952-0 | F +49 208 4952-264


Company / customer
Project description EG-VA655526/111-0530/3GD
Drawing number
Commission 100004339

Manufacturer (company)	Hans Turck GmbH & Co. KG	Manufacturer (company)	
Path		Path	Zone 2
Project name	ID 100004339_V2	Protection class	IP66
Make	EG-VA655526/111-0530/3GD	Power supply	230VAC
Type	remote I/O System excom	Supply line	
Place of installation	Zone 2	Control voltage	24VDC
Responsible for project	Hans Turck GmbH & Co. KG		
Part feature		Year of manufacture	



Created on	25.02.2019		
Edit date	06.09.2022	by (short name) Claus.Vogel	Number of pages 9

Parts list


SR. NO.	DEVICE TAG	QTY.	PART DESCRIPTION	MANUFACTURER	PART NUMBER	TYPE NUMBER
1	-*-PS1	0	Alternative power supply, 24V, 5A to Phoenix QUINT-PS Alternative Stromversorgung, 24V, 5A zu Phoenix QUINT-PS	PULS	PULS.CP5.241-*	CP5.241-*
2	-*-PS2	0	Alternative power supply, 24V, 5A to Phoenix QUINT-PS Alternative Stromversorgung, 24V, 5A zu Phoenix QUINT-PS	PULS	PULS.CP5.241-*	CP5.241-*
3	-CABINET_BASE	1	Stainless Steel Cabinet (650 x 550 x 260) Edelstahlgehäuse (650 550 x 260)	ROSE Systemtechnik GmbH	ROSE.A20672	A20672
4	-CABINET_DOOR	1	Stainless Steel Door with Window (650 x 550 x 260) Edelstahltür mit Fenster (650 x 550 x 260)	ROSE Systemtechnik GmbH	ROSE.A20674	A20674
5	-FLANGE	1	Flange for ROSE cabinet 650x550x260 Flanschplatte für ROSE Gehäuse 650x550x260	ROSE Systemtechnik GmbH	ROSE.FLANGE_65XX26_1X1_V2	FLANGE_65XX26_1X1_V2
6	-FLANGE_BREATHER	1	M20 Breather/Drainer with stainless steel castled nut M20 Entlüfter/Ablass mit Kronenmutter aus Edelstahl	RST Rabe-System-Technik	RST.DP-E-4-0-04-S3	DP-E-4-0-04-S3
7	-FLANGE_GLAND_M16_BU	96	PU Giant Ex-e Blue M16 PU Kabelverschraubung Ex-e Blue M16	WISKA Hoppmann GmbH	WISKA.ESKE/1-i 16	ESKE/1-i 16
8	-FLANGE_GLAND_M20_BU	4	PU Giant Ex-e Blue M20 PU Kabelverschraubung Ex-e Blue M20	WISKA Hoppmann GmbH	WISKA.ESKE/1-i 20	ESKE/1-i 20
9	-FLANGE_GLAND_M25_BK	4	PU Gland Ex-e Black M25 PU Kabelverschraubung Ex-e Black M25	WISKA Hoppmann GmbH	WISKA.ESKE/1-e 25	ESKE/1-e 25
10	-MT	1	excom I/O System, Module Rack, Zone 2, for 16 Modules I/O System excom, Zone-2-Modulträger für 16 Module	Hans Turck GmbH & Co KG	TUR.9100681	MT16-3G
11	-PS1	1	Power supply, with protective coating Stromversorgung, schutzlackiert	Phoenix Contact	PXC.2320908	QUINT-PS/1AC/24DC/ 5/CO
12	-PS2	1	Power supply, with protective coating Stromversorgung, schutzlackiert	Phoenix Contact	PXC.2320908	QUINT-PS/1AC/24DC/ 5/CO
13	-X	5	End clamp Endhalter	Phoenix Contact	PXC.3022276	CLIPFIX 35-5
14	-X1	2	Feed-through terminal block Durchgangsklemme	Phoenix Contact	PXC.3044160	UT 10
15	-X1	2	Feed-through terminal block Durchgangsklemme	Phoenix Contact	PXC.3044188	UT 10 BU
16	-X1	2	Ground modular terminal block Schutzleiter-Reihenklemme	Phoenix Contact	PXC.3044173	UT 10-PE
17	-X1	2	End clamp Endhalter	Phoenix Contact	PXC.3022276	CLIPFIX 35-5




DOOR VIEW




RIGHT VIEW




MOUNTING VIEW




LEFT VIEW











			Date	25.02.2019	100004339			MT PWR Wiring			=		
			Ed.	Pune-SWaknis	EG-VA655526/111-0530/3GD						+ EXCOM_RIO		
			Appr										Page
Modification	Date	Name	Original		Replacement of	Replaced by						Page	9